

# INDOOR AIR QUALITY SURVEY

**SAMPLING LOCATION:**

East Pennsboro High School  
425 West Shady Lane  
Enola, Pennsylvania

**SAMPLING DATE:**

August 3, 2017

**PREPARED FOR:**

Mr. Chad Reigle  
East Pennsboro Area School District  
890 Valley Street  
Enola, Pennsylvania 17025

**CALI PROJECT NUMBER:**

17-1081-009

**REPORT DATE:**

August 7, 2017

**Survey Performed By:**



---

Richard E. Roush, CIAQM  
Project Manager

---

125 Frytown Road  
Carlisle, Pennsylvania 17015  
Phone: (717) 379-3782  
Fax: (717) 776-6436

E-Mail: [rroush@caassociates.net](mailto:rroush@caassociates.net) [www.cumberlandanalyticallabs.com](http://www.cumberlandanalyticallabs.com)

# Table of Contents

Executive Summary: .....	2
Unusual Mold Expiations:.....	2
Methods and Analysis – Air Sampling: .....	2
Standards – Bacterial/Mold:.....	2
Survey Results:.....	3
Recommendations:.....	3
Non-Viable Mold Spore Trap Sample Results Table #1: .....	4
Non-Viable Mold Spore Trap Sample Results Table #2: .....	5
Non-Viable Mold Spore Trap Sample Results Table #3: .....	6
Mold Definitions: .....	7

**Executive Summary:**

In August 2017, Cumberland Analytical Laboratories, Inc. (CALI) was contracted by the East Pennsboro Area School District to perform an Indoor Air Quality Survey at the East Pennsboro High School. This survey consisted of the collection of air samples for airborne fungal contaminants on August 3, 2017, by Richard E. Roush, CIAQM, Project Manager of Cumberland Analytical Laboratories, Inc.

---

**Unusual Mold Expiations:**

The results table listed below showed that **unusual mold conditions exist** in **1 of the samples**. Please refer to the individual sample results (Page 4, Page 5 and Page 6) for more detailed information regarding these individual samples.

Sample No.	Sample Location	Sample Type	Unusual Mold Conditions Exist
01	Outside	Mold Air	N/A
02	English Hallway 2 <sup>nd</sup> Floor by Faculty	Mold Air	No
03	Room 214	Mold Air	No
<b>04</b>	<b>Corridor by Stairwell D</b>	<b>Mold Air</b>	<b>Yes</b>
05	Room 123 Storage	Mold Air	No
06	Hallway by Room 120	Mold Air	No
07	Room 129	Mold Air	No
08	Library	Mold Air	No
09	Cafeteria	Mold Air	No
010	Board Room	Mold Air	No

---

**Methods and Analysis – Air Sampling:**

Particle air sampling techniques were used. Air samples were collected using a calibrated high volume-sampling pump and Allergenco D Cassettes. Sample analysis provided by Environmental Hazard Services, located in Richmond, Virginia.

The samples were packaged for proper shipment and delivered to EHS Laboratories an American Industrial Hygiene Association (AIHA) accredited laboratory located out of Richmond, Virginia. *While the results and information of this analysis are considered to be reliable, CALI assumes no responsibility for the accuracy of these results.*

---

**Standards – Bacterial/Mold:**

There are no current Permissible Exposure Levels or Safe Levels established by OSHA or NIOSH.

EPA has guidelines on mold remediation in schools yet no clearance levels have been established. Molds are a major source of indoor allergens. Molds can also trigger asthma. Even when dead or unable to grow, mold can cause health effects such as allergic reactions. The types and severity of health effects associated with exposure to mold depend, in part, on the type of mold present and the extent of the occupants' exposure and existing sensitivities or allergies. Prompt and effective remediation of moisture problems is essential to minimize potential mold exposures and their potential health effects.

Statistically, total spore counts are always significantly correlated with counts conducted on Agar Plate samples. On average, total mold spore to culturable mold ratios are in the range of 10:1. A concentration dominated by one genus such as Penicillium or Aspergillus even at 10,000 Particles/m<sup>3</sup> is unacceptable. Total levels should not exceed 2,000 Particles/m<sup>3</sup>, and each individual count should not exceed 650 Particles/m<sup>3</sup>. For remediation, a reduction of airborne spores based upon Pre and Post sampling, compared to exterior sample results, and *no evidence of mold* growth present is the goal.

---

**Survey Results:**

The result of the Non-Viable Spore Trap Sample collected on 08/03/2017, **showed that unusual mold condition exists in 1 of the samples (Sample #4)**. Please refer to the individual sample results as listed on Page 4, Page 5 and Page 6 of this report, for more detailed information regarding this individual sample.

---

**Recommendations:**

It is recommended that to lower the total spore counts in this area, good housekeeping practices should be intensified while including the use of a bio-cide cleaning solution and HEPA vacuuming. Housekeeping is an effective measure to maintain Indoor Air Quality within a structure, as well as minimize the release of harmful materials into the structure that will negatively affect Indoor Air Quality. Cleaning and sterilizing activities also will decrease the risk of exposure to biological growth and contamination. Also, an air scrubber containing a HEPA filter should be used during and after the cleanup for a minimum of 24-36 hours at which time the areas should be retested to ensure that airborne fungal populations have been lowered to acceptable levels.

---

**Indoor Air Quality Survey Report for the East Pennsboro Area School District**  
**East Pennsboro High School on August 3, 2017**  
**CALI Project Number: 17-1081-009**  
**Report Date: August 7, 2017**  
**Page 4**

**Non-Viable Mold Spore Trap Sample Results Table #1:**

Spore ID	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)
	Cladosporium Spores	27	360	18	240	9	120	6	80	26
Penicillium/Aspergillus Group Spores	8	110	2	27	10	130	98	1300	7	93
Alternaria Spores	0	0	0	0	2	27	0	0	1	13
Aureobasidium Spores	0	0	0	0	0	0	1	13	0	0
Pyricularia Spores	0	0	0	0	0	0	0	0	1	13
Torula Spores	1	13	0	0	1	13	0	0	0	0
Pithomyces Spores	2	27	1	13	0	0	1	13	0	0
Epicoccum Spores	1	13	0	0	0	0	0	0	0	0
Cercospora Spores	2	27	0	0	0	0	0	0	1	13
Fusarium Spores	1	13	0	0	0	0	0	0	0	0
Smuts, Periconia, Myxomycetes	9	120	1	13	7	93	1	13	7	93
<b>Total Spores (Spores/m3)</b>	----	<b>680</b>	----	<b>290</b>	----	<b>390</b>	----	<b>1400</b>	----	<b>570</b>

**Indoor Air Quality Survey Report for the East Pennsboro Area School District**  
**East Pennsboro High School on August 3, 2017**  
**CALI Project Number: 17-1081-009**  
**Report Date: August 7, 2017**  
**Page 5**

**Non-Viable Mold Spore Trap Sample Results Table #2:**

Lab No. Client Sample ID: Date Collected: Collection Location: Sampling Media: Analytical Sensitivity spores/m3: Volume (L):	17-08-00647-001 01 08/03/2017 OUTSIDE Air-O-Cell 13.3 75		17-08-00647-006 06 08/03/2017 Hallway by Room 120 Air-O-Cell 13.3 75		17-08-00647-007 07 08/03/2017 Room 129 Air-O-Cell 13.3 75		17-08-00647-008 08 08/03/2017 Library Air-O-Cell 13.3 75		17-08-00647-009 09 08/03/2017 Cafeteria Air-O-Cell 13.3 75	
Spore ID	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)
Cladosporium Spores	27	360	7	93	23	310	30	400	10	130
Penicillium/Aspergillus Group Spores	8	110	52	690	4	53	16	210	8	110
Alternaria Spores	0	0	0	0	0	0	2	27	0	0
Aureobasidium Spores	0	0	0	0	1	13	0	0	0	0
Curvularia Spores	0	0	0	0	0	0	0	0	1	13
Stachybotrys Spores	0	0	0	0	0	0	0	0	1	13
Torula Spores	1	13	0	0	0	0	0	0	0	0
Pithomyces Spores	2	27	3	40	0	0	2	27	0	0
Epicoccum Spores	1	13	0	0	1	13	0	0	0	0
Cercospora Spores	2	27	0	0	0	0	0	0	0	0
Nigrospora Spores	0	0	0	0	0	0	1	13	0	0
Fusarium Spores	1	13	1	13	0	0	0	0	0	0
Trichoderma Spores	0	0	0	0	0	0	9	120	0	0
Smuts, Periconia, Myxomycetes	9	120	2	27	1	13	5	67	2	27
<b>Total Spores (Spores/m3)</b>	----	<b>680</b>	----	<b>870</b>	----	<b>400</b>	----	<b>870</b>	----	<b>290</b>

**Indoor Air Quality Survey Report for the East Pennsboro Area School District**  
**East Pennsboro High School on August 3, 2017**  
**CALI Project Number: 17-1081-009**  
**Report Date: August 7, 2017**  
**Page 6**

---

**Non-Viable Mold Spore Trap Sample Results Table #3:**

<b>Lab No.</b> <b>Client Sample ID:</b> <b>Date Collected:</b> <b>Collection Location:</b> <b>Sampling Media:</b> <b>Analytical Sensitivity spores/m3:</b> <b>Volume (L):</b>	17-08-00641-010 01 08/03/2017 OUTSIDE Air-O-Cell 13.3 75		17-08-00641-009 010 08/03/2017 Board Room Air-O-Cell 13.3 75	
Spore ID	Raw Count	Results (Spores/m3)	Raw Count	Results (Spores/m3)
Cladosporium Spores	27	1360	83	1100
Peronospora/Oidium Spores	0	0	1	13
Penicillium/Aspergillus Group Spores	5	110	4	53
Alternaria Spores	0	0	4	53
Drechslera/Bipolaris Group Spores	0	0	1	13
Pyricularia Spores	0	0	2	27
Curvularia Spores	0	0	2	27
Torula Spores	1	13	0	0
Pithomyces Spores	2	27	5	67
Epicoccum Spores	1	13	3	40
Cercospora Spores	2	27	1	13
Nigrospora Spores	0	0	3	40
Fusarium Spores	1	13	0	0
Smuts, Periconia, Myxomycetes	9	120	5	67
<b>Total Spores (Spores/m3)</b>	----	<b>680</b>	----	<b>1500</b>

**Mold Definitions:**

Spore Name	Description
Cladosporium Spores	Reported to be allergenic. Most commonly identified spore in outdoor samples. Highly seasonal. Indoor species may differ from outdoor species. Typically found inside supply ducts.
Peronospora/Oidium Spores	No information regarding the health effects of this genus is available at this time. All mold should be treated as potential allergens.
Penicillium/Aspergillus Group Spores	Reported to be allergenic. Many species have been documented to produce mycotoxins, which may be associated with pulmonary disease in humans and other animals. Research studies have implicated several of these toxins as carcinogens in laboratory animals following inhalation. A wide number of organisms have been grouped into these two genera. Extremely difficult to identify down to species level. Typically identified in soil, cellulose, food, paint, compost piles, carpeting, wallpaper and in the fiberglass insulation used in interior ductwork.
Alternaria Spores	Reported to be allergenic. Commonly found growing in carpets and on indoor textiles. This fungi has been indicated as a potential cause of hypersensitivity pneumonitis. Rare species known to produce tenuazonic acid and other toxic metabolites that may cause disease in humans.
Aureobasidium Spores	Reported to be allergenic. Commonly found in high moisture areas such as bathrooms and kitchens. Rarely associated with skin disorders.
Drechslera/Bipolaris Group Spores	Toxigenic. Also recognized as an allergen. Under certain conditions, these fungi have been documented to produce the mycotoxin, sterigmatocystin. Studies have indicated that this toxin may cause damage to the liver and kidneys in laboratory animals.
Pyricularia Spores	No information regarding the health effects of this genus is available at this time. All mold should be treated as potential allergens.
Curvularia Spores	Reported to be allergenic. No additional health data for this genus is available at this time.
Stachybotrys Spores	Toxigenic. Also recognized as an allergen. Typically a fungus of dark green/black coloration, it grows readily on building materials with a high cellulose content but low in nitrogen, and is rarely observed in outdoor samples. Certain strains of Stachybotrys may produce the mycotoxin, trichothecene under appropriate conditions which has been documented to cause problems associated with the circulatory, alimentary, skin and nervous systems. Absorption of trichothecene into the tissues of the human lung may cause a condition known as pneumomycosis. Although there have been conflicting studies concerning the toxicity of this fungi, it still appears that extreme caution should be practiced when dealing with this mold.
Torula Spores	Toxigenic. Also recognized as an allergen. Studies have shown that certain species may produce a toxin in the laboratory.
Chaetomium Spores	Reported to be allergenic. Some species may be associated with disease in humans. Commonly found on the paper used as facing on sheetrock.
Pithomyces Spores	Reported to be allergenic. Some species may, in rare instances, produce the toxin sporidesmin.
Epicoccum Spores	Reported to be allergenic. Commonly found on plants, textiles and products made of paper.
Cercospora Spores	No information regarding the health effects of this genus is available at this time. All molds should be treated as potential allergens.
Nigrospora Spores	Reported to be allergenic. No additional health data for this genus is available at this time.
Fusarium Spores	Toxigenic. Also recognized as an allergen. Certain species of Fusarium may produce the mycotoxin, trichothecene, under appropriate conditions, which has been documented to cause problems associated with the circulatory, alimentary, skin and nervous systems. Absorption of trichothecene into the tissues of the human lung may cause a condition known as pneumomycosis. Symptoms may appear following exposure from either inhalation or ingestion. Rarely connected to infections of the eye, skin and nails.
Trichoderma Spores	Toxigenic. Also recognized as an allergen. May produce certain antibodies known to be toxic to humans. Grows well on cellulose products and building materials.
Smuts, Periconia, Myxomycetes	Reported to be allergenic. This class of fungal spores is most often related to agriculture and plant disease and is rarely found indoors.
Stemphylium Spores	Reported to be allergenic. No additional health data for this genus is available at this time.